



# Certificate of Conformity

Certificate no.: P2212018-UKCA

Applicant: GLACIALTECH INC.

Trade mark: 

Address: 7 Fl, No. 352, Sec. 2, Jung Shan Rd., Jung He Dist., New Taipei City, Taiwan, 235, R.O.C

Product: LED Driver

Model no.: GP-CVP150P-xxVyyy-T01, GP-CVP150P-xxVyyy-P01 (xx = 12, 24, 36 or 48 ; yyy = any character or number or blank)

Parameter: Input rating: See following table for the details

Output rating: See following table for the details

		GP-CVP150-12Vyyy series	GP-CVP150-24Vyyy series	GP-CVP150-36Vyyy series	GP-CVP150-48Vyyy series
Input Rating		100-240 Vac, 50-60 Hz, 1.8 A			
Output Rating	(For I/P : 100-200Vac)	12V, 10A, 120W	24V, 5.0A, 120W	36V, 3.35A, 120.6W	48V, 2.5A, 120W
	(For I/P : 200-240Vac)	12V, 11A, 132W	24V, 6.25A, 150W	36V, 4.2A, 151.2W	48V, 3.15A, 151.2W

Protection class: Class II

Ambient temperature: ta=45°C

Test standard(s): BS EN 61347-2-13:2014+A1:2017 used in conjunction with BS EN 61347-1:2015+A1:2021

Test report no.: P2212018-LVD

Date: 2023-10-11

This UKCA-Compliance of Conformity is issued on a voluntary basis according to Electrical Equipment (Safety) Regulations 2016 relating to electrical equipment design for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the Directive. It refers only to the particular sample submitted for testing and compliance.

Approved by:



Kent Fang  
Director  
i-Tek Electronics Corp